



Ref. No. IMQ-062/E-CTF2  
Issue No: 1

# RECOGNITION

WE DECLARE THAT

**PALAZZOLI S.p.A.**

IN ITS TESTING LABORATORY

**TEST LABORATORY**  
Via F. Palazzoli, 31  
IT – 25128 Brescia (BS)

*HAS BEEN RECOGNIZED FOR THE APPLICATION OF PROCEDURE*

## **CUSTOMERS' TESTING FACILITIES (CTFs) STAGE 2**

AS DESCRIBED IN INTERNATIONAL DOCUMENTS *IECEE OD-2048 / ETICS OD-ECS 032* AND IN *IMQ RULES FOR RECOGNITION AND UTILIZATION OF TESTING FACILITIES* IN THE PERFORMING OF TESTS COVERED IN THE SCOPE REPORTED IN THE ANNEX OF THIS RECOGNITION

**(PRODUCT CATEGORIES: INST – POW)**

IMQ S.p.A. will accept the test results of the above testing laboratory as basis to issue its own certifications

---

**IMQ S.p.A**

First issue..... : 2021-11-08  
Current issue..... : 2022-11-08  
Replaces..... : 2021-11-08  
Expiry date..... : 2023-11-07

THE VALIDITY OF THIS RECOGNITION IS SUBJECTED TO THE CONTINUOUS RESPECT OF RELEVANT IMQ RULES AND IS RELEVANT TO THE STANDARDS LISTED IN THE ANNEX TO THIS RECOGNITION

## Scope of the CTF

| Category | Standard  | Details   |
|----------|---|---|
| INST     | <ul style="list-style-type: none"> <li>IEC 60309-1:1999 + A1:2005 + A2:2012</li> <li>EN 60309-1:1999 + A1:2007 + A2:2012</li> </ul> | All clauses except 29, 30   |
|          | <ul style="list-style-type: none"> <li>IEC 60309-1:2021</li> <li>EN IEC 60309-1:2022</li> </ul>                                     | All clauses except 29, 30   |
|          | <ul style="list-style-type: none"> <li>IEC 60309-2:1999 + A1:2005 + A2:2012</li> <li>EN 60309-2:1999 + A1:2007 + A2:2012</li> </ul> | All clauses except 29, 30   |
|          | <ul style="list-style-type: none"> <li>IEC 60309-2:2021</li> <li>EN IEC 60309-2:2022</li> </ul>                                     | All clauses except 29, 30   |
|          | <ul style="list-style-type: none"> <li>IEC 60309-4:2006 + A1:2012</li> <li>EN 60309-4:2007 + A1:2012</li> </ul>                     | All clauses except 29, 30   |
|          | <ul style="list-style-type: none"> <li>IEC 60309-4:2021</li> <li>EN IEC 60309-4:2022</li> </ul>                                     | All clauses except 29, 30   |
|          | <ul style="list-style-type: none"> <li>IEC 62208:2011</li> <li>EN 62208:2011</li> </ul>   | All clauses except 9.5, 9.12, 9.13  |
| POW      | <ul style="list-style-type: none"> <li>IEC 60947-1:2007 + A1:2010 + A2:2014</li> <li>EN 60947-1:2007 + A1:2011 + A2:2014</li> </ul> | Accepted clauses 5, 7.1.2.2, 8.3.3.3, 8.3.3.4 (excluded impulse withstand voltage), 8.3.3.6, 8.3.3.7                |
|          | <ul style="list-style-type: none"> <li>IEC 60947-1:2020</li> <li>EN IEC 60947-1:2021</li> </ul>                                     | Accepted clauses 8.1.2.2, 8.1.12 + Annex C, 9.3.3.3, 9.3.3.4 (excluded impulse withstand voltage), 9.3.3.6, 9.3.3.7 |
|          | <ul style="list-style-type: none"> <li>IEC 60947-3:2008 + A1:2012 + A2:2015</li> <li>EN 60947-3:2009 + A1:2012 + A2:2015</li> </ul> | Accepted clauses 5, 7.1.2.2 Test Sequence II (8.3.4.1, 8.3.4.2, 8.3.4.3, 8.3.4.4), 8.5.1, 8.5.2                     |
|          | <ul style="list-style-type: none"> <li>IEC 60947-3:2020</li> <li>EN IEC 60947-3:2021</li> </ul>                                     | Accepted clauses 8.1.2.2, Test Sequence II (9.3.5.2, 9.3.5.3, 9.3.5.4, 9.3.5.5), 9.5.2, 9.5.3                       |

## **Terms of recognition**

The acceptance of the test results is subjected to the following terms and conditions:

- testing program falling in the "Scope of recognition";
- selected parts of each testing session witnessed by IMQ engineers;
- continuous conformance of quality system and facilities of the testing laboratory with the IMQ requirements.

First issue..... : 2021-11-08

Current issue..... : 2022-11-08

Replaces..... : 2021-11-08

Expiry date..... : 2023-11-07